



U.S. DEPARTMENT OF
ENERGY

THIS
HOME'S
SCORE **2**
OUT OF 10

THIS HOME'S ESTIMATED
ENERGY COSTS

\$3,475
PER YEAR

HOME PROFILE

LOCATION:

12146 SW 29th Ave
Portland, OR 97219

YEAR BUILT:

1956

HEATED FLOOR AREA:

1,800 sq.ft.

NUMBER OF BEDROOMS:

3

ASSESSMENT

ASSESSMENT DATE:

04/12/2018

SCORE EXPIRATION DATE:

04/12/2026

ASSESSOR:

Jan-michael Barlow
Portland Energy Assessors / Four
Walls Inc.

PHONE:

503-547-7139

EMAIL:

jan@
portlandenergyassessors.com


LICENSE #:

146968

*Flip over to learn how
to improve this score
and use less energy!*



Home Energy Score



Official Assessment | ID# 200986

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.

HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 10,342 kWh/yr. \$1,411

Natural Gas: 0 therms/yr. \$0

Other: \$2,064

Renewable Generation: (\$0)

TOTAL ENERGY COSTS PER YEAR \$3,475

How much
**renewable
energy** does
this home
generate?

_____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



What should my home's carbon footprint be? Between now and 2030, Portlanders should reduce carbon pollution per household to 3 metric tons per year to reach our climate goals.

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices (\$0.14/kwh for electricity; \$1.17/therm for natural gas; \$4.00/gal for heating oil; \$2.43/gal for propane).
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- Relisting 2-7 years after the assessment date requires a free reprint of the Report from us.greenbuildingregistry.com to update energy and carbon information.
- **This report meets Oregon's Home Energy Performance Score Standard and complies with Portland City Code Chapter 17.108.**

Score
today:

2

Score with priority
improvements:

9

Estimated **energy savings**
with priority improvements:

\$1,702 PER
YEAR

Estimated **carbon reduction**
with priority improvements:

47% PER
YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- ☒ Get your home energy assessment. Done!
- ☐ Choose energy improvements from the list of recommendations below.
- ☐ Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout **www.energytrust.org/findacontractor** or call toll free **1-866-368-7878**.
- ☐ Explore financing options at **energytrust.org**.
- ☐ Visit **energytrust.org/solutions/insulation-and-air-sealing/** for changes you can make today.

PRIORITY ENERGY IMPROVEMENTS ¹

FEATURE	TODAY'S CONDITION ⁴	RECOMMENDED IMPROVEMENTS ³
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Attic insulation	Ceiling insulated to R-11	Insulate to R-38 or R-49 if code requires it
Basement wall insulation 550 ft ²	Insulated to R-0	Insulate framed wall cavities, Insulate masonry or concrete walls to R-15
Duct insulation	Un-insulated	Insulate to R-8
Duct sealing	Un-sealed	Reduce leakage to a maximum of 10% of total airflow
Wall insulation	Insulated to R-0	Fully insulate wall cavities
Floor insulation 700 ft ²	Insulated to R-0	Insulate to R-30 or fill floor cavity
Heating equipment	Oil furnace 78% AFUE	When replacing, upgrade to ENERGY STAR
Water Heater	Electric EF 0.87	When replacing, upgrade to ENERGY STAR, (EF>=2.67 or UEF>= 2.67)

ADDITIONAL ENERGY RECOMMENDATIONS ²

FEATURE	TODAY'S CONDITION ⁴	RECOMMENDED IMPROVEMENTS
Air Conditioner	N/A	
Foundation wall insulation	N/A	
Knee Wall insulation	N/A	
Skylights	N/A	
Solar PV	N/A	
Windows	Multiple types	When replacing, upgrade to ENERGY STAR

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. If your home has an oil furnace it is recommended you replace it with a high efficiency electric heat pump.

4. Today's Condition represents the majority condition for that feature in the home.